

**From:** Isam Hasenin  
**To:** Escobar-Eck, Marcela  
**Date:** 12/19/2006 1:25:45 PM  
**Subject:** sunroad

---

Marcela,

Joe tells me that you're about to sign a letter allowing them to do work in the roof area. I have reviewed the plans with senior structural staff and would recommend against allowing any work in the topmost floor, the roof, and penthouse.

Thank You,  
Isam Hasenin, P. E., C. B. O.  
Chief Building Official, City of San Diego  
ihasenin@sandiego.gov  
619-446-5406

**From:** Isam Hasenin  
**To:** Escobar-Eck, Marcela  
**Date:** 12/21/2006 7:26:56 AM  
**Subject:** here it is:

---

here it is:

If it were determined that the top 20 feet of the structure is to be removed, all portions of the structure above the floor level of the 11th floor must be removed to accommodate the rebuilding of the elevator penthouse to be within the FAA maximum height of 160 feet. Therefore, it is not advisable to do any construction beyond the floor level of the 11th floors.

Thank You,  
Isam Hasenin, P. E., C. B. O.  
Chief Building Official, City of San Diego  
ihasenin@sandiego.gov  
619-446-5406